

Evidence of Performance

Air permeability, Watertightness, Resistance to wind load



Test Report

No. 15-000354-PR01

(PB-A01-02-en-01)

Client	Kale Kilit ve Kalip Sanayi A.S Atatürk Caddesi Basak SK. No. 39 Güngören 34610 Istanbul Turkey
Product	Tilt and turn window
System	Special design
Performance-relevant product details	Material: PVC/U white Hardware: Kale Safir Çift Açılım sistemi
Overall dimensions (W x H)	900 mm x 1300 mm
Special features	-

Basis

EN 14351-1:2006+A1:2010

Test standard/s:

EN 1026:2000-06

EN 1027:2000-06

EN 12211:2000-06

Correspond/s to the national standard/s (e.g. DIN EN)

Representation



Results

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Class 4A

Resistance to wind load according to EN 12210:1999-11/AC:2002-08



Class C5 / B5

ift Rosenheim

27.05.2015

Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Construction Product Testing

Herbert Hageneder, Dipl.-Ing. (FH)
Operating Testing Officer
Construction Product Testing

Instructions for use

The results obtained can be used by the manufacturer for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The provisions of the applicable product standard have to be observed.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 21 pages.